

# Emission Test Certificate

Friday June 27<sup>th</sup>, 2008

Supplier: Global Ventures Australia Pty Ltd (PO Box 186 Glenorie NSW 2157)

Sample Description: EcoCore® White Birch Multiply (melamin glue)

Date Tested: June 2008

Test Method: ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data:

<b>Specification</b> <b>Green Building Council of Australia</b> <b>Green Star Office Interiors V1.1 IEQ -12</b>	<b>Eco-Core® White Birch</b> <b>Multiply (melamin glue)</b>
Formaldehyde	0.033 mg/m <sup>2</sup> /hr



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant

CV080621