

Emission Test Certificate

Friday June 27th, 2008

Supplier: Global Ventures Australia Pty Ltd (PO Box 186 Glenorie NSW 2157)

Sample Description: EcoCore® White Birch Multiply (phenolic glue)

Date Tested: June 2008

Test Method: ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data:

Specification Green Building Council of Australia Green Star Office Interiors V1.1 IEQ -12	Eco-Core® White Birch Multiply (phenolic glue)
Formaldehyde	0.030 mg/m ² /hr



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

CV080621